
A MEMBER OF THE STOHL GROUP OF COMPANIES

February 3, 2017

David Spacone
City School District of the City of Niagara Falls
Director of Facilities
630 – 66th Street
Niagara Falls, NY 14304

Re: Follow-Up Sampling of Drinking Water for Lead Concentrations

Dear Mr. Spacone:

Included with this letter is Stohl Environmental LLC's report for the follow-up Water Sampling performed at the educational buildings of the City School District of the City of Niagara Falls:

- Hyde Park Elementary School, 1620 Hyde Park Boulevard, Niagara Falls, New York

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

Initial Sampling and Analysis: In Compliance with NYS regulations, initial first draw water sampling was completed on 9/24/2016 and 10 samples were identified as containing lead concentrations above the NYS Action Level of 15 ppb.

Mitigation by District and Follow-up Sampling by Stohl Environmental LLC:

- Following the receipt of initial sampling results, in accordance with guidance received from NYS, the District is reported to have prohibited use of the outlets analyzed as above the NYS Action Level of 15 ppb until "(1) a lead remediation plan is implemented... and (2) test results indicate that the lead levels are at or below the action level".
- Subsequent to reported mitigation by the District, Stohl Environmental LLC was requested to perform follow-up sampling and laboratory analysis.
- Follow-up sampling was performed by Stohl Environmental LLC in accordance with the requirements and protocols outlined in NYS regulations, as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

A MEMBER OF THE STOHL GROUP OF COMPANIES

Results of Follow-up Sampling: As further detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the follow-up sampling and analysis performed, the following is reported:

- **Follow-up First Draw Samples:** Following reported remediation by the District, and for confirmatory purposes, 10 outlets were re-sampled on 11/8/2016 and analyzed by a certified and independent laboratory. **Of the 10 samples collected, 5 contained lead concentrations above the action level.**

Interpretation of First Draw Sampling Results: Under NYSDOH regulations Section 67-4.4, for the (5) outlets that continue to have First Draw test results above the NYS Action Level, the District must “prohibit use of the outlet until lead remediation is implemented and (First Draw) test results indicate that lead levels are at or below the Action Level.”

- **Flush Samples:** As additional confirmation of lead concentrations, and in an attempt to determine whether lead concentrations above the Action Level result from the outlet/fixture or from the plumbing to the outlet, 10 flush samples were also collected from these same outlets on 11/8/2016 and submitted to and analyzed by a certified and independent laboratory. All 10 sample results indicated lead concentrations were below the action level.

Interpretation of Flush Sampling Results: As detailed in EPA guidance (“3T’s for Reducing Lead in Drinking Water in Schools”), *“If initial test results reveal lead concentrations greater than (the action level) for a given outlet, follow-up flush testing... is recommended to determine if the lead contamination results are from the fixture or from the plumbing.”*

Based upon this guidance, for the (5) outlets tested on 11/8/16 that continue to have First Draw Sample lead concentrations above the Action Level, the Flush Sample results infer that the source of lead at these outlets is the fixture, rather than the plumbing to the fixture.

Thank you for the opportunity to be of service to City School District of the City of Niagara Falls.

Sincerely,
Stohl Environmental, LLC.



William K. Sisco
Senior Project Manager

**Follow-Up Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

**David Spacone
City School District of the City of Niagara Falls
Director of Facilities
630 – 66th Street
Niagara Falls, NY 14304**

Prepared by:



ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES

4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219

☎ (716) 312-0070 📠 (716) 312-8092

www.stohlenvironmental.com

Conditions as of November 8, 2016



4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.1 Sampling Protocol and Summary of Results:

Stohl Environmental was retained by City School District of the City of Niagara Falls to perform follow-up sampling and analysis of potable water outlets that were identified in report dated 10/21/2016 as having lead concentrations greater than the NYS action level of 15 ppb. Sampling was performed in the following buildings:

- Hyde Park Elementary School, 1620 Hyde Park Boulevard, Niagara Falls, New York

Scope of Work:

Stohl Environmental was charged with collecting follow-up water samples from outlets which previously were analyzed as having lead concentrations above 15 ppb in the Hyde Park Elementary School Building. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **‘3Ts for Reducing Lead in Drinking Water in Schools’**, Stohl Environmental’s protocol can be summarized as follows:

- **Follow-up Samples** were collected to verify initial findings of lead contaminations, to assist in problem assessment to determine remediation, and/or verify that lead levels are at or below action level post-remediation. Confirmatory samples were collected as follows:
 - **Follow-up First-Draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
 - **To supplement follow-up first draw samples, in some instances, Flush samples** of 250 mL were collected from cold water outlets after the outlet was run for 30 seconds before any water was used or following a second first-draw sample at the same outlet. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
 - **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by Initial First Draw & Follow-up Samples

Building Name	Date of Sample Events	Total Number Samples Collected	Initial First Draw Samples		Follow-up Samples			
			Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb	First Draw Samples		Flush Samples	
					Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb	Analyzed at or Below Action Level of 15 ppb	Analyzed Above Action Level of 15 ppb
Hyde Park Elementary School Building	9/24/2016, 11/1/2016 and 11/8/2016	97	67	10	5	5	10	0

** Follow-up samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

A MEMBER OF THE STOHL GROUP OF COMPANIES

Sample Results: Initial First Draw, Follow-up First Draw and Flush Samples

Sample #	Sample Type (Initial First Draw, Follow-up First Draw or Flush)	Sample Location	Fixture/Outlet type	Laboratory Analysis in ppb
111.6-8	Initial First Draw	Classroom 2 Bathroom	Sink	78.1
111.6-8R	Follow-Up First Draw	Classroom 2 Bathroom	Sink	8.23
111.6-8F	Flush	Classroom 2 Bathroom	Sink	8.19
111.6-10	Initial First Draw	Classroom 3	Bubbler	22.7
111.6-10R	Follow-Up First Draw	Classroom 3	Bubbler	8.97
111.6-10F	Flush	Classroom 3	Bubbler	< 5.00
111.6-12	Initial First Draw	Handicapped Bathroom	Sink	39.7
111.6-12-1R	Follow-Up First Draw	Handicapped Bathroom	Sink	< 5.00
111.6-12F	Flush	Handicapped Bathroom	Sink	< 5.00
111.6-19	Initial First Draw	Classroom 11 Closest to the Entry Door	Sink	18.4
111.6-19R	Follow-Up First Draw	Classroom 11 Closest to the Entry Door	Sink	24.9
111.6-19F	Flush	Classroom 11 Closest to the Entry Door	Sink	< 5.00
111.6-43	Initial First Draw	Boy's Gym	Drinking Fountain	23.5
111.6-43R	Follow-Up First Draw	Boy's Gym	Drinking Fountain	< 5.00
111.6-43F	Flush	Boy's Gym	Drinking Fountain	< 5.00
111.6-44	Initial First Draw	PEG Kitchen	Sink	156
111.6-44R	Follow-Up First Draw	PEG Kitchen	Sink	78.7
111.6-44F	Flush	PEG Kitchen	Sink	< 5.00
111.6-47	Initial First Draw	CO Gym	Drinking Fountain	17.4
111.6-47R	Follow-Up First Draw	CO Gym	Drinking Fountain	14.2
111.6-47F	Flush	CO Gym	Drinking Fountain	< 5.00
111.6-48	Initial First Draw	Men's Bathroom	Sink	105
111.6-48R	Follow-Up First Draw	Men's Bathroom	Sink	36.5
111.6-48F	Flush	Men's Bathroom	Sink	6.27



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

Sample #	Sample Type (Initial First Draw, Follow-up First Draw or Flush)	Sample Location	Fixture/Outlet type	Laboratory Analysis in ppb
111.6-49	Initial First Draw	Speech Room	Sink	26.1
111.6-49R	Follow-Up First Draw	Speech Room	Sink	29.6
111.6-49F	Flush	Speech Room	Sink	< 5.00
111.6-71	Initial First Draw	Outside Room C5	Hose Bib	30.7
111.6-71R	Follow-Up First Draw	Outside Room C5	Hose Bib	18.2
111.6-71F	Flush	Outside Room C5	Hose Bib	8.11

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.4 Laboratory Analytical Reports by Building



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 190821

Matrix: Water
Received: 11/03/16
Analyzed: 01/23/17
Reported: 01/24/17

Attn:
Project: Hyde Park Elementary
Location: 1620 Hyde Park Blvd
Number: 2016L-111.6

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location Method, Sample Date, Result, RL*, Units, Analyst. Rows include sample IDs 190821-001 through 190821-014 with corresponding lead levels and locations like C2B2, C3, HBR, C11, Boys Gym, PEG Kitchen, CO Gym.

*Reporting Limit (RL). All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Values are reported to three significant figures. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 190821

Matrix: Water
Received: 11/03/16
Analyzed: 01/23/17
Reported: 01/24/17

Attn:
Project: Hyde Park Elementary
Location: 1620 Hyde Park Blvd
Number: 2016L-111.6

PO Number:

Table with 8 columns: Sample ID, Cust. Sample ID, Location Method, Sample Date, Result, RL*, Units, Analyst. Rows include Lead samples with results like < 5.00, 36.5, 6.27, 29.6, 18.2, 8.11.

190821-01/24/17 08:45 AM

Abisola O Kasali
Reviewed By: Abisola Kasali
Metals Supervisor

*Reporting Limit (RL). All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Values are reported to three significant figures. The test results reported relate only to the samples submitted.



Analysis Report

Schneider Laboratories Global, Inc

2512 W. Cary Street • Richmond, Virginia • 23220-5117
804-353-6778 • 800-785-LABS (5227) • Fax 804-359-1475

Customer: Stohl Environmental, LLC (4507)
Address: 4169 Allendale Parkway
Blasdell, NY 14219

Order #: 192729

Matrix: Drinking Water
Received: 11/18/16
Reported: 11/28/16

Attn:
Project: Hyde Park Elem
Location: 1620 Hyde Park Blvd
Number: 2016L-111.16

PO Number:

Table with columns: Sample ID, Cust. Sample ID, Location, Method, Result, RL*, Units, Analysis Date, Analyst. Row 1: 192729-001, 111.6-12-1R, HBR, EPA 200.9 Rev 2.2, <5.00, 5.00, µg/L, 11/25/16, SA. Section: Metals Analysis.

192729-11/28/16 03:47 PM

Marti H. Baird (handwritten signature)

Reviewed By: Marti Baird
Analyst

EPA Regulatory Limits

Table with columns: Parameter, Reg. Limit, Unit. Row 1: Lead, 15.0, µg/L

Certifications

Table with columns: Parameter, Method, Matrix, CA, CT, FL, NJ, NY, RI, VA. Row 1: Lead, EPA 200.9 Rev 2.2, Drinking Water, X, X, X, X, X, X, X

Key

Table with columns: State, Regulatory Agency - Lab ID, Certificate Number. Rows for CA, CT, FL, NJ, NY, RI, VA.

'X' indicates that the analyte is accredited.
If your state is not listed above, call laboratory for accreditation/certification information.

All internal QC parameters were met. Unusual sample conditions, if any, are described. Surrogate Spike results designated with "D" indicate that the analyte was diluted out. "MI" indicates matrix interference. Concentration and *Reporting Limit (RL) based on areas provided by client. Values are reported to three significant figures. Solid PPM = mg/kg | PPB = µg/kg and Water PPM = mg/L | PPB = µg/L. The test results reported relate only to the samples submitted.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued September 22, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Lead, Total

EPA 200.9 Rev. 2.2



Serial No.: 55043

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES NON POTABLE WATER
All approved analytes are listed below:*

Metals I

Lead, Total
EPA 200.7 Rev. 4.4
EPA 6010C
EPA 7000B
EPA 200.9 Rev. 2.2

Sample Preparation Methods

EPA 3010A
EPA 3005A
EPA 3020A



Department
of Health

Serial No.: 54667

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2003) for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved analytes are listed below:*

Characteristic Testing

TCLP EPA 1311

Polychlorinated Biphenyls

PCB-1268 EPA 8082A

Metals I

Sample Preparation Methods

Barium, Total EPA 6010C

EPA 3010A

Cadmium, Total EPA 6010C

EPA 3050B

Chromium, Total EPA 6010C

EPA 3550C

Lead, Total EPA 6010C

EPA 3031

EPA 7000B

Nickel, Total EPA 6010C

Silver, Total EPA 6010C

Metals II

Antimony, Total EPA 6010C

Arsenic, Total EPA 6010C

Chromium VI EPA 7196A

Mercury, Total EPA 7471B

Selenium, Total EPA 6010C

Polychlorinated Biphenyls

PCB-1016 EPA 8082A

PCB-1221 EPA 8082A

PCB-1232 EPA 8082A

PCB-1242 EPA 8082A

PCB-1248 EPA 8082A

PCB-1254 EPA 8082A

PCB-1260 EPA 8082A

PCB-1262 EPA 8082A

NEW
YORK
STATE

Department
of Health

Serial No.: 54668

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:*

Miscellaneous

Asbestos in Friable Material	EPA 600/M4/82/020
Asbestos in Non-Friable Material-PLM	Item 198.6 of Manual (NOB by PLM)
Lead in Dust Wipes	EPA 7000B
Lead in Paint	EPA 7000B

Sample Preparation Methods

EPA 3050B



Serial No.: 54669

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2017
Issued April 01, 2016

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. FAYEZ ABOUZAKI
SCHNEIDER LABORATORIES GLOBAL, INC
2512 WEST CARY STREET
RICHMOND, VA 23220-5117

NY Lab Id No: 11413

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES AIR AND EMISSIONS
All approved subcategories and/or analytes are listed below:*

Metals I

Lead, Total NIOSH 7082
40 CFR PART 50 1984 APP G

Miscellaneous

Fibers NIOSH 7400 A RULES



Serial No.: 54670

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway
Buffalo, New York 14219
(P) 716-312-0070 (F) 716-312-8092
www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

1.6 Chains of Custody



Chain of Custody Document

ENVIRONMENTAL CONSULTANTS - A MEMBER OF THE STOHL GROUP OF COMPANIES
 4169 ALLENDALE PKWY. BUFFALO, NEW YORK 14219
 ☎ (716) 312-8070 傳 (716) 312-8092
 www.stohlenvironmental.com

Submitted to: (Lab Name) SLG

STOHL Job # 2016L-111.6

Client: Niagara Falls CSD

Contact: Dave Spacone

Building: Hyde Park Elementary

Location: 1620 Hyde Park Blvd, Niagara Falls, NY

LEAD

Water by AAS-GF: ASTM D3559-03D, US EPA 200.9 X

Turnaround
5 Days

Sample #	Location	Outlet Type	Time	Cooler Model	Lab ID	Results
111.6-8R	C2B2	s	6:30	NA	190821 s 20 V:\190\190821 vjones 11/3/2016 1:17:00 PM Federal Express 77761 1755341	
111.6-8F	C2B2	s	6:30	NA		
111.6-10R	C3	b	6:32	NA		
111.6-10F	C3	b	6:32	NA		
111.6-12R	HBR	s	6:38	NA		
111.6-12F	HBR	s	6:39	NA		
111.6-19R	C11	s	6:35	NA		
111.6-19F	C11	s	6:36	NA		
111.6-43R	boys gym	df	6:42	NA		
111.6-43F	boys gym	df	6:42	NA		
111.6-44R	PEG Kitchen	s	6:44	NA		
111.6-44F	PEG Kitchen	s	6:44	NA		
111.6-47R	CO gym	df	6:47	NA		
111.6-47F	CO gym	df	6:47	NA		
111.6-48R	mbr	s	6:49	NA		
111.6-48F	mbr	s	6:49	NA		
111.6-49R	speech room	s	6:50	NA		
111.6-49F	speech room	s	6:51	NA		

Notes:

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: _____

Sampled By: Mike Irwin Print Name Stohl Env: Mike Irwin Date: 11/1/2016
 Relinquished By: [Signature] Print Name Stohl Env: Joseph Mecca Date: 11/1/2016
 Received (Name / Lab): _____ Date: _____ Time: _____
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

