



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-03-05627

Received Date: 03/25/2021
Reported Date: 04/22/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-149.10; LaSalle Prep; 7436 Buffalo Ave; Niagara Falls, NY 14304

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-05627-001	149.10-6	03/18/2021	RM 318 LEFT OF DOOR	1.36	04/22/2021	
21-03-05627-002	149.10-7	03/18/2021	RM 318 NEAR WALL RIGHT SINK	1.43	04/22/2021	
21-03-05627-003	149.10-8	03/18/2021	RM 318 RIGHT WALL LEFT SINK	11.1	04/22/2021	
21-03-05627-004	149.10-9	03/18/2021	RM 318 RIGHT WALL RIGHT SINK	10.4	04/22/2021	
21-03-05627-005	149.10-10	03/18/2021	RM 319	9.34	04/22/2021	
21-03-05627-006	149.10-11	03/18/2021	RM 320 LEFT OF DOOR	51.6	04/22/2021	
21-03-05627-007	149.10-12	03/18/2021	RM 320 RIGHT WALL LEFT SINK	28.0	04/22/2021	
21-03-05627-008	149.10-13	03/18/2021	RM 320 RIGHT WALL RIGHT SINK	21.2	04/22/2021	
21-03-05627-009	149.10-14	03/18/2021	DRINKING FOUNTAIN	2.64	04/22/2021	
21-03-05627-010	149.10-16	03/18/2021	RM 323	2.40	04/22/2021	
21-03-05627-011	149.10-17	03/18/2021	GIRLS LAV 3RD FLOOR	1.12	04/22/2021	
21-03-05627-012	149.10-20	03/18/2021	BOYS LAV 3RD FLOOR LEFT	2.07	04/22/2021	
21-03-05627-013	149.10-21	03/18/2021	BOYS LAV 2ND FLOOR	1.73	04/22/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-05627

Project/Test Address: 2020L-149.10; LaSalle Prep; 7436 Buffalo Ave; Niagara Falls, NY 14304

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-05627-014	149.10-22	03/18/2021	RM 219	1.16	04/22/2021	
21-03-05627-015	149.10-24	03/18/2021	RM 219	188	04/22/2021	
21-03-05627-016	149.10-28	03/18/2021	RM 223	1.55	04/22/2021	
21-03-05627-017	149.10-29	03/18/2021	GIRLS LAV 2ND FLOOR LEFT	<1.00	04/22/2021	
21-03-05627-018	149.10-33	03/18/2021	DRINKING FOUNTAIN	1.54	04/22/2021	
21-03-05627-019	149.10-35	03/18/2021	TEACHERS LOUNGE LEFT BR	<1.00	04/22/2021	
21-03-05627-020	149.10-36	03/18/2021	TEACHERS LOUNGE RIGHT BR	<1.00	04/22/2021	
21-03-05627-021	149.10-37	03/18/2021	TEACHERS LOUNGE MAIN	1.32	04/22/2021	
21-03-05627-022	149.10-40	03/18/2021	RM 119	1.10	04/22/2021	
21-03-05627-023	149.10-41	03/18/2021	DRINKING FOUNTAIN	2.02	04/22/2021	
21-03-05627-024	149.10-42	03/18/2021	KITCHEN LEFT DOUBLE SINK	1.90	04/22/2021	
21-03-05627-025	149.10-43	03/18/2021	KITCHEN RIGHT DOUBLE SINK	2.29	04/22/2021	
21-03-05627-026	149.10-44	03/18/2021	KITCHEN KITCHEN STAFF BR	9.17	04/22/2021	
21-03-05627-027	149.10-45	03/18/2021	KITCHEN DISHWASH SINK	<1.00	04/22/2021	
21-03-05627-028	149.10-46	03/18/2021	KITCHEN COMBITHERM SPRAYER	1.59	04/22/2021	
21-03-05627-029	149.10-47	03/18/2021	KITCHEN OFFICE ICE MACHINE	<1.00	04/22/2021	
21-03-05627-030	149.10-48	03/18/2021	KITCHEN KETTLE FILL	3.14	04/22/2021	
21-03-05627-031	149.10-50	03/18/2021	BOYS LAV 1ST FLOOR LEFT	<1.00	04/22/2021	
21-03-05627-032	149.10-51	03/18/2021	BOYS LAV 1ST FLOOR RIGHT	<1.00	04/22/2021	
21-03-05627-033	149.10-53	03/18/2021	GIRLS LOCKER RM LEFT	<1.00	04/22/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-05627

Project/Test Address: 2020L-149.10; LaSalle Prep; 7436 Buffalo Ave; Niagara Falls, NY 14304

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-05627-034	149.10-54	03/18/2021	GIRLS LOCKER RM RIGHT	<1.00	04/22/2021	
21-03-05627-035	149.10-55	03/18/2021	GIRLS LOCKER RM LEFT	<1.00	04/22/2021	
21-03-05627-036	149.10-56	03/18/2021	GIRLS LOCKER RM LEFT MIDDLE	<1.00	04/22/2021	
21-03-05627-037	149.10-57	03/18/2021	GIRLS LOCKER RM RIGHT MIDDLE	<1.00	04/22/2021	
21-03-05627-038	149.10-58	03/18/2021	GIRLS LOCKER RM RIGHT	<1.00	04/22/2021	
21-03-05627-039	149.10-59	03/18/2021	EXERCISE RM	6.20	04/22/2021	
21-03-05627-040	149.10-60	03/18/2021	TEACHERS LOUNGE	2.17	04/22/2021	
21-03-05627-041	149.10-64	03/18/2021	BOYS LOCKER RM LEFT	1.13	04/22/2021	
21-03-05627-042	149.10-65	03/18/2021	BOYS LOCKER RM LEFT MIDDLE	<1.00	04/22/2021	
21-03-05627-043	149.10-66	03/18/2021	BOYS LOCKER RM RIGHT MIDDLE	<1.00	04/22/2021	
21-03-05627-044	149.10-67	03/18/2021	BOYS LOCKER RM RIGHT	<1.00	04/22/2021	
21-03-05627-045	149.10-70	03/18/2021	FACULTY RM MAIN	<1.00	04/22/2021	
21-03-05627-046	149.10-71	03/18/2021	FACULTY RM BR	<1.00	04/22/2021	
21-03-05627-047	149.10-78	03/18/2021	3RD FLOOR BOYS BR RIGHT	2.75	04/22/2021	
21-03-05627-048	149.10-79	03/18/2021	2ND FLOOR BOYS BR LEFT MIDDLE	1.25	04/22/2021	
21-03-05627-049	149.10-80	03/18/2021	2ND FLOOR BOYS BR RIGHT MIDDLE	2.38	04/22/2021	
21-03-05627-050	149.10-81	03/18/2021	2ND FLOOR BOYS BR RIGHT	1.22	04/22/2021	
21-03-05627-051	149.10-82	03/18/2021	1ST FLOOR GIRLS LEFT MIDDLE	<1.00	04/22/2021	
21-03-05627-052	149.10-83	03/18/2021	1ST FLOOR GIRLS RIGHT MIDDLE	<1.00	04/22/2021	
21-03-05627-053	149.10-84	03/18/2021	1ST FLOOR GIRLS RIGHT	<1.00	04/22/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-05627

Project/Test Address: 2020L-149.10; LaSalle Prep; 7436 Buffalo Ave; Niagara Falls, NY 14304

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-05627-054	149.10-85	03/18/2021	1ST FLOOR BOYS RIGHT MIDDLE	<1.00	04/22/2021	
21-03-05627-055	149.10-86	03/18/2021	1ST FLOOR BOYS RIGHT	<1.00	04/22/2021	
21-03-05627-056	149.10-87	03/18/2021	1ST FLOOR TEACHERS LOUNGE RIGHT	1.77	04/22/2021	

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-149.10

Client: Niagara Falls CSD

Contact: Earl Smeal

Building: LaSalle Prep

Location: 7436 Buffalo Ave, Niagara Falls, NY 14304

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
149.10-6	RM 318 - Left of Door	S	0:15
149.10-7	RM 318 - Near Wall Right Sink	S	0:16
149.10-8	RM 318 - Right Wall Left Sink	S	0:17
149.10-9	RM 318 - Right wall right sink	S	0:18
149.10-10	RM 319	S	0:19
149.10-11	RM 320 - Left of door	S	0:20
149.10-12	RM 320 - Right wall left Sink	S	0:21
149.10-13	RM 320 - Right wall Right sink	S	0:22
149.10-14	Drinking Fountain	DF	0:23
149.10-16	RM 323	S	0:24
149.10-17	Girls Lav 3rd Floor	S	0:25
149.10-20	Boys Lav 3rd Floor Left	S	0:26
149.10-21	Boys Lav 2nd Floor	S	0:27
149.10-22	RM 219	S	0:28
149.10-24	RM 219	S	0:29
149.10-28	RM 223	S	0:30
149.10-29	GIRLS LAV 2nd Floor Left	S	0:31
149.10-33	Drinking Fountain	DF	0:33

21-03-05627



Due Date:
04/22/2021
(Thursday)
AE

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/18/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/22/2021

Received (Name / Lab): T. Smeal Date: 3/25/21 Time: 4:30

Sample Login (Name / Lab): T. Smeal / Paul Nichols Date: 4/16/21 Time: 9:04 AM

Analysis (Name / Lab): Young, D. Date: 4/22/21 Time: 1:14 PM

QA/QC Review (Name / Lab): M. Smeal Date: 4/22/21 Time: 1:52 PM

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-149.10

Client: Niagara Falls CSD

Contact: Earl Smeal

Building: LaSalle Prep

Location: 7436 Buffalo Ave, Niagara Falls, NY 14304

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
149.10-35	Teachers Lounge Left BR	S	0:34
149.10-36	Teachers Lounge Right BR	S	0:35
149.10-37	Teachers Lounge Main	S	0:36
149.10-40	RM 119	S	0:37
149.10-41	Drinking Fountain	DF	0:38
149.10-42	Kitchen - Left Double Sink	S	0:39
149.10-43	Kitchen - Right Double Sink	S	0:40
149.10-44	Kitchen - Kitchen Staff BR	S	0:41
149.10-45	Kitchen - Dishwash Sink	S	0:42
149.10-46	Kitchen - Combitherm sprayer	S	0:43
149.10-47	Kitchen Office - Ice Machine	IM	0:44
149.10-48	Kitchen - Kettle Fill	S	0:45
149.10-50	Boys Lav 1st floor left	S	0:46
149.10-51	Boys Lav 1st floor right	S	0:47
149.10-53	Girls Locker RM left	DF	0:48
149.10-54	Girls Locker RM Right	DF	0:49
149.10-55	Girls locker RM Left	S	0:50
149.10-56	Girls Locker RM left middle	S	0:51

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Paul Nichols Date: 3/18/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/22/2021

Received (Name / Lab): T. Schmitt Date: 3/25/21 Time: 4:38p

Sample Login (Name / Lab): T. Schmitt / Paul Nichols Date: 4/16/21 Time: 9:27am

Analysis (Name / Lab): Sony Duce Date: 4/21/21 Time: 1:14p

QA/QC Review (Name / Lab): Michael Date: 4/22/21 Time: 2:50p

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-149.10

Client: Niagara Falls CSD

Contact: Earl Smeal

Building: LaSalle Prep

Location: 7436 Buffalo Ave, Niagara Falls, NY 14304

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
149.10-57	Girls Locker RM right middle	S	0:52
149.10-58	Girls Locker RM Right	S	0:53
149.10-59	Exercise RM	S	0:54
149.10-60	Teachers Lounge	S	0:55
149.10-64	Boys locker RM Left	S	0:56
149.10-65	Boys Locker RM left middle	S	0:57
149.10-66	Boys Locker RM right middle	S	0:58
149.10-67	Boys Locker RM Right	S	0:59
149.10-70	Faculty RM main	S	1:00
149.10-71	Faculty RM BR	S	1:01
149.10-78	3rd Floor Boys BR Right	S	1:02
149.10-79	2nd Floor boys BR Left Middle	S	1:03
149.10-80	2nd Floor boys BR Right Middle	S	1:04
149.10-81	2nd Floor Boys BR Right	S	1:05
149.10-82	1st Floor Girls Left Middle	S	1:06
149.10-83	1st Floor Girls Right Middle	S	1:07
149.10-84	1st Floor Girls Right	S	1:08
149.10-85	1st Floor Boys Right Middle	S	1:09

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/18/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/22/2021

Received (Name / Lab): Traci Bloom / Green Bay Date: 3/25/21 Time: 4:30p

Sample Login (Name / Lab): Traci Bloom / Green Bay Date: 4/1/21 Time: 9:31 AM

Analysis (Name / Lab): Gary O'Connell Date: 4/2/21 Time: 1:14p

QA/QC Review (Name / Lab): Melinda Date: 4/2/21 Time: 2:50pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

