



Environmental Hazards Services, L.L.C.  
 7469 Whitepine Rd  
 Richmond, VA 23237  
 Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

**Client:** Stohl Environmental  
 3860 California Road  
 Orchard Park, NY 14127

**Report Number:** 21-03-05655  
**Received Date:** 03/25/2021  
**Reported Date:** 04/22/2021  
**Sampled By:** Paul Nichols  
**Tech Certification #:**

**Project/Test Address:** 2020L-149.2; Cataract Elementary School; 6431 Girard Ave; Niagara Falls, NY 14304

**Client Number:**  
 33-5980

# Laboratory Results

**Fax Number:**  
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-05655-001	149.2-3	03/18/2021	KITCHEN LEFT FAUCET ON TRIPLE SINK	<1.00	04/22/2021	
21-03-05655-002	149.2-4	03/18/2021	KITCHEN RIGHT FAUCET ON TRIPLE SINK	<1.00	04/22/2021	
21-03-05655-003	149.2-5	03/18/2021	KITCHEN SINGLE ISLAND SINK	<1.00	04/22/2021	
21-03-05655-004	149.2-6	03/18/2021	KITCHEN HAND WASHING SINK	10.1	04/22/2021	
21-03-05655-005	149.2-7	03/18/2021	WOMENS BATHROOM OUTSIDE KITCHEN	2.64	04/22/2021	
21-03-05655-006	149.2-8	03/18/2021	MENS BATHROOM OUTSIDE KITCHEN	3.11	04/22/2021	
21-03-05655-007	149.2-10	03/18/2021	BOYS BATHROOM LEFT SINK	<1.00	04/22/2021	
21-03-05655-008	149.2-12	03/18/2021	BOYS BATHROOM CENTER SINK	<1.00	04/22/2021	
21-03-05655-009	149.2-13	03/18/2021	BOYS BATHROOM RIGHT SINK	<1.00	04/22/2021	
21-03-05655-010	149.2-14	03/18/2021	STAFF BATHROOM NEAR BOYS BATHROOM	<1.00	04/22/2021	
21-03-05655-011	149.2-15	03/18/2021	STAFF BATHROOM NEAR GIRLS BATHROOM	<1.00	04/22/2021	
21-03-05655-012	149.2-16	03/18/2021	GIRLS BATHROOM LEFT SINK	<1.00	04/22/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-03-05655

**Project/Test Address:** 2020L-149.2; Cataract Elementary School; 6431 Girard Ave; Niagara Falls, NY 14304

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-05655-013	149.2-17	03/18/2021	GIRLS BATHROOM CENTER SINK	<1.00	04/22/2021	
21-03-05655-014	149.2-18	03/18/2021	GIRLS BATHROOM RIGHT SINK	<1.00	04/22/2021	
21-03-05655-015	149.2-19	03/18/2021	103	<1.00	04/22/2021	
21-03-05655-016	149.2-20	03/18/2021	103 BATHROOM	1.19	04/22/2021	
21-03-05655-017	149.2-21	03/18/2021	120	<1.00	04/22/2021	
21-03-05655-018	149.2-22	03/18/2021	122	1.21	04/22/2021	
21-03-05655-019	149.2-23	03/18/2021	113	<1.00	04/22/2021	
21-03-05655-020	149.2-24	03/18/2021	MAIN OFFICE STORE ROOM	<1.00	04/22/2021	
21-03-05655-021	149.2-25	03/18/2021	162	<1.00	04/22/2021	
21-03-05655-022	149.2-26	03/18/2021	140	1.72	04/22/2021	
21-03-05655-023	149.2-27	03/18/2021	GYM	<1.00	04/22/2021	
21-03-05655-024	149.2-28	03/18/2021	GIRLS LOCKER ROOM LEFT	14.1	04/22/2021	
21-03-05655-025	149.2-29	03/18/2021	GIRLS LOCKER ROOM CENTER	5.66	04/22/2021	
21-03-05655-026	149.2-30	03/18/2021	BOYS LOCKER ROOM	4.96	04/22/2021	
21-03-05655-027	149.2-31	03/18/2021	BOYS LOCKER ROOM	2.85	04/22/2021	
21-03-05655-028	149.2-32	03/18/2021	BOYS LOCKER ROOM	2.95	04/22/2021	
21-03-05655-029	149.2-35	03/18/2021	GYM BATHROOM	<1.00	04/22/2021	
21-03-05655-030	149.2-37	03/18/2021	BOYS BATHROOM LEFT ACROSS FROM 173	<1.00	04/22/2021	
21-03-05655-031	149.2-38	03/18/2021	BOYS BATHROOM CENTER ACROSS FROM 173	<1.00	04/22/2021	
21-03-05655-032	149.2-39	03/18/2021	BOYS BATHROOM RIGHT ACROSS FROM 173	<1.00	04/22/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-03-05655

**Project/Test Address:** 2020L-149.2; Cataract Elementary School; 6431 Girard Ave; Niagara Falls, NY 14304

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-05655-033	149.2-40	03/18/2021	STAFF BATHROOM ACROSS FROM 173	<1.00	04/22/2021	
21-03-05655-034	149.2-41	03/18/2021	STAFF BATHROOM ACROSS FROM 173	<1.00	04/22/2021	
21-03-05655-035	149.2-42	03/18/2021	GIRLS BATHROOM LEFT ACROSS FROM 173	<1.00	04/22/2021	
21-03-05655-036	149.2-43	03/18/2021	GIRLS BATHROOM CENTER ACROSS FROM 173	<1.00	04/22/2021	
21-03-05655-037	149.2-44	03/18/2021	GIRLS BATHROOM RIGHT ACROSS FROM 173	<1.00	04/22/2021	
21-03-05655-038	149.2-45	03/18/2021	STEM LAB	1.83	04/22/2021	
21-03-05655-039	149.2-46	03/18/2021	STEM LAB SMALL ROOM LEFT SINK	1.63	04/22/2021	
21-03-05655-040	149.2-48	03/18/2021	183 LEFT SINK	3.96	04/22/2021	
21-03-05655-041	149.2-49	03/18/2021	184 SINK FACING HALLWAY	5.14	04/22/2021	
21-03-05655-042	149.2-50	03/18/2021	184 SINK FACING OUTSIDE	2.24	04/22/2021	
21-03-05655-043	149.2-51	03/18/2021	HALL OUTSIDE 184	<1.00	04/22/2021	
21-03-05655-044	149.2-52	03/18/2021	190 SINK MOST TOWARDS HALL	2.14	04/22/2021	
21-03-05655-045	149.2-53	03/18/2021	190 2ND SINK FROM HALL	2.12	04/22/2021	
21-03-05655-046	149.2-54	03/18/2021	190 3RD SINK FROM HALL	1.16	04/22/2021	
21-03-05655-047	149.2-55	03/18/2021	190 4TH SINK FROM HALL	5.19	04/22/2021	
21-03-05655-048	149.2-56	03/18/2021	185 SINK FACING OUTSIDE	18.9	04/22/2021	
21-03-05655-049	149.2-57	03/18/2021	186	2.69	04/22/2021	
21-03-05655-050	149.2-63	03/18/2021	KITCHEN TRIPLE SINK SPRAYER	1.29	04/22/2021	
21-03-05655-051	149.2-64	03/18/2021	POT FILL	4.99	04/22/2021	
21-03-05655-052	149.2-65	03/18/2021	GIRLS COACH'S OFFICE	2.04	04/22/2021	

# Environmental Hazards Services, L.L.C

**Client Number:** 33-5980

**Report Number:** 21-03-05655

**Project/Test Address:** 2020L-149.2; Cataract Elementary School; 6431 Girard Ave; Niagara Falls, NY 14304

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-05655-053	149.2-66	03/18/2021	BOYS COACH'S OFFICE	2.80	04/22/2021	
21-03-05655-054	149.2-67	03/18/2021	ROOM 183 RIGHT SINK	35.8	04/22/2021	

**Method:** EPA 200.8

**Analyst:** Anthony Dee

**Accreditation #:** NY 11714

Reviewed By Authorized Signatory:

*Melissa Kanode*

*Missy Kanode*

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-149.2

Client: Niagara Falls CSD

Contact: Earl Smeal


Building: Cataract Elementary School

Location: 6431 Girard Ave. Niagara Falls, NY 14304

**LEAD**  
 Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround  
20 Days

Sample #	Location	Outlet Type	Time
149.2-3	Kitchen - Left faucet on triple sink	S	3:45
149.2-4	Kitchen - Right faucet on triple sink	S	3:46
149.2-5	Kitchen - Single island sink	S	3:47
149.2-6	Kitchen - Hand washing sink	S	3:48
149.2-7	Womens bathroom - Outside kitchen	S	3:49
149.2-8	Men's bathroom - Outside kitchen	S	3:50
149.2-10	Boys bathroom - Left sink	S	3:51
149.2-12	Boys bathroom - Center sink	S	3:52
149.2-13	Boys bathroom - Right sink	S	3:53
149.2-14	Staff bathroom - Near boys bathroom	S	3:54
149.2-15	Staff bathroom - Near girls bathroom	S	3:55
149.2-16	Girls bathroom - Left sink	S	3:56
149.2-17	Girls bathroom - Center sink	S	3:57
149.2-18	Girls bathroom - Right sink	S	3:58
149.2-19	103	S	3:59
149.2-20	103 bathroom	S	4:00
149.2-21	120	S	4:01
149.2-22	122	S	4:02

21-03-05655 

Due Date:  
 04/22/2021  
 (Thursday)  
 AE

Notes:  
 Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)  If checked, also e-mail results to: [Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/18/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/22/2021

Received (Name / Lab): T. Cohen Date: 3/25/21 Time: 5

Sample Login (Name / Lab): Traci Bloom / Traci Bloom Date: 4/16/21 Time: 9:12 AM

Analysis (Name / Lab): Young Dice Date: 4/22/21 Time: 3:20 PM

QA/QC Review (Name / Lab): M. White Date: 4/22/21 Time: 9:14 AM

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

5699



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-149.2

Client: Niagara Falls CSD

Contact: Earl Smeal

Building: Cataract Elementary School

Location: 6431 Girard Ave. Niagara Falls, NY 14304

**LEAD**

Water by SM 19, 21 - 23 3113B (-04, -10) X

*Turnaround*

20 Days

Sample #	Location	Outlet Type	Time
149.2-23	113	S	4:03
149.2-24	Main Office store room	S	4:04
149.2-25	162	S	4:05
149.2-26	140	S	4:06
149.2-27	Gym	DF	4:07
149.2-28	Girls locker room - Left	Sink	4:08
149.2-29	Girls locker room - Center	Sink	4:09
149.2-30	Boys locker room	S	4:10
149.2-31	Boys locker room	S	4:11
149.2-32	Boys locker room	S	4:12
149.2-35	Gym Bathroom	S	4:12
149.2-37	Boys bathroom - Left, across from 173	S	4:13
149.2-38	Boys bathroom - Center, across from 173	S	4:14
149.2-39	Boys bathroom - Right, across from 173	S	4:15
149.2-40	Staff bathroom - across from 173	S	4:16
149.2-41	Staff bathroom - across from 173	S	4:17
149.2-42	Girls bathroom - Left, across from 173	S	4:18
149.2-43	Girls bathroom - Center, across from 173	S	4:19

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/18/2021

Relinquished By: Eric Henderson Jr Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/22/2021

Received (Name / Lab): Trohn Date: 3/25/21 Time: 8

Sample Login (Name / Lab): Traci Bloom / Lisa Bar Date: 4/11/21 Time: 9:16

Analysis (Name / Lab): Stacy Dice Date: 4/22/21 Time: 3:30pm

QA/QC Review (Name / Lab): Melinda Date: 4/22/21 Time: 9:14

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

655



# Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-149.2

Client: Niagara Falls CSD

Contact: Earl Smeal

Building: Cataract Elementary School

Location: 6431 Girard Ave. Niagara Falls, NY 14304

**LEAD**

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
149.2-44	Girls bathroom - Right, across from 173	S	4:20
149.2-45	STEM lab	S	4:21
149.2-46	STEM lab small room - Left sink	S	4:22
149.2-48	183 - Left Sink	S	4:23
149.2-49	184 - Sink facing hallway	S	4:24
149.2-50	184 - Sink facing outside	S	4:25
149.2-51	Hall outside 184	DF	4:26
149.2-52	190 - Sink most towards hall	S	4:27
149.2-53	190 - 2nd sink from hall	S	4:28
149.2-54	190 - 3rd sink from hall	S	4:29
149.2-55	190 - 4th sink from hall	S	4:30
149.2-56	185 - Sink facing outside	S	4:31
149.2-57	186	S	4:32
149.2-63	Kitchen Triple Sink Sprayer	S	4:33
149.2-64	Pot Fill	S	4:34
149.2-65	Girls Coach's Office	S	4:35
149.2-66	Boys Coach's Office	S	4:36
149.2-67	Room 183 - Right Sink	S	4:37

Notes:

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com)

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 3/18/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/22/2021

Received (Name / Lab): T. Smeal Date: 3/25/21 Time: 8

Sample Login (Name / Lab): Traai Bloom / Laci Bloom Date: 4/16/21 Time: 9:19 AM

Analysis (Name / Lab): Young O. Oel Date: 4/22/21 Time: 3:30 PM

QA/QC Review (Name / Lab): M. Smeal Date: 4/22/21 Time: 9:14

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_