



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-03-03739

Received Date: 03/17/2021
Reported Date: 04/14/2021
Sampled By: Drew Theal
Tech Certification #:

Project/Test Address: 2020L-149.9; Gaskill Prep; 910 Hyde Parke Blvd; Niagara Falls, NY

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03739-001	149.9-1	03/09/2021	RM 406	150	04/12/2021	
21-03-03739-002	149.9-3	03/09/2021	RM 400	15.7	04/10/2021	
21-03-03739-003	149.9-5	03/09/2021	GIRL'S LAV	<1.00	04/10/2021	
21-03-03739-004	149.9-6	03/09/2021	GIRL'S LAV	<1.00	04/10/2021	
21-03-03739-005	149.9-7	03/09/2021	GIRL'S LAV	1.33	04/10/2021	
21-03-03739-006	149.9-8	03/09/2021	GIRL'S LAV	<1.00	04/10/2021	
21-03-03739-007	149.9-9	03/09/2021	GIRL'S LAV	<1.00	04/10/2021	
21-03-03739-008	149.9-14	03/09/2021	BOY'S LAV	1.86	04/10/2021	
21-03-03739-009	149.9-15	03/09/2021	BOY'S LAV	1.19	04/10/2021	
21-03-03739-010	149.9-16	03/09/2021	BOY'S LAV	1.80	04/10/2021	
21-03-03739-011	149.9-17	03/09/2021	BOY'S LAV	1.76	04/10/2021	
21-03-03739-012	149.9-18	03/09/2021	BOY'S LAV	1.69	04/10/2021	
21-03-03739-013	149.9-21	03/09/2021	RM 325	<1.00	04/10/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03739

Project/Test Address: 2020L-149.9; Gaskill Prep; 910 Hyde Parke Blvd;
Niagara Falls, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03739-014	149.9-22	03/09/2021	RM 323	<1.00	04/10/2021	
21-03-03739-015	149.9-23	03/09/2021	RM 323	<1.00	04/10/2021	
21-03-03739-016	149.9-24	03/09/2021	RM 323	4.93	04/10/2021	
21-03-03739-017	149.9-25	03/09/2021	RM 322	33.1	04/11/2021	
21-03-03739-018	149.9-26	03/09/2021	CAFETERIA	2.32	04/10/2021	
21-03-03739-019	149.9-27	03/09/2021	CAFETERIA	12.3	04/10/2021	
21-03-03739-020	149.9-28	03/09/2021	CAFETERIA	3.63	04/10/2021	
21-03-03739-021	149.9-29	03/09/2021	CAFETERIA	3.10	04/10/2021	
21-03-03739-022	149.9-30	03/09/2021	KITCHEN	1.09	04/10/2021	
21-03-03739-023	149.9-31	03/09/2021	KITCHEN	1.90	04/10/2021	
21-03-03739-024	149.9-32	03/09/2021	KITCHEN	15.2	04/11/2021	
21-03-03739-025	149.9-33	03/09/2021	KITCHEN	2.99	04/10/2021	
21-03-03739-026	149.9-34	03/09/2021	KITCHEN	1.18	04/10/2021	
21-03-03739-027	149.9-35	03/09/2021	KITCHEN	2.31	04/10/2021	
21-03-03739-028	149.9-36	03/09/2021	KITCHEN	2.16	04/10/2021	
21-03-03739-029	149.9-37	03/09/2021	KITCHEN	1.05	04/10/2021	
21-03-03739-030	149.9-39	03/09/2021	GIRL'S LAV	<1.00	04/10/2021	
21-03-03739-031	149.9-40	03/09/2021	GIRL'S LAV	<1.00	04/10/2021	
21-03-03739-032	149.9-43	03/09/2021	GIRL'S LAV	2.04	04/10/2021	
21-03-03739-033	149.9-44	03/09/2021	MEN'S LAV	2.51	04/10/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03739

Project/Test Address: 2020L-149.9; Gaskill Prep; 910 Hyde Parke Blvd;
Niagara Falls, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03739-034	149.9-46	03/09/2021	RM 210B	<1.00	04/10/2021	
21-03-03739-035	149.9-47	03/09/2021	WOMEN'S LAV	2.76	04/11/2021	
21-03-03739-036	149.9-48	03/09/2021	WOMEN'S LAV	1.56	04/10/2021	
21-03-03739-037	149.9-50	03/09/2021	BOY'S LAV	4.41	04/10/2021	
21-03-03739-038	149.9-51	03/09/2021	BOY'S LAV	3.69	04/10/2021	
21-03-03739-039	149.9-52	03/09/2021	BOY'S LAV	1.18	04/10/2021	
21-03-03739-040	149.9-53	03/09/2021	BOY'S LAV	<1.00	04/10/2021	
21-03-03739-041	149.9-54	03/09/2021	BOY'S LAV	<1.00	04/10/2021	
21-03-03739-042	149.9-57B	03/09/2021	GIRL'S GYM	<1.00	04/10/2021	
21-03-03739-043	149.9-58B	03/09/2021	BOY'S GYM	<1.00	04/10/2021	
21-03-03739-044	149.9-61	03/09/2021	BOY'S LOCKER ROOM	<1.00	04/10/2021	
21-03-03739-045	149.9-62	03/09/2021	BOY'S LOCKER ROOM	<1.00	04/10/2021	
21-03-03739-046	149.9-65	03/09/2021	GIRL'S LOCKER ROOM	<1.00	04/10/2021	
21-03-03739-047	149.9-66	03/09/2021	GIRL'S LOCKER ROOM	<1.00	04/10/2021	
21-03-03739-048	149.9-67	03/09/2021	RM 101	61.4	04/10/2021	
21-03-03739-049	149.9-68	03/09/2021	RM 103	4.35	04/10/2021	
21-03-03739-050	149.9-69	03/09/2021	RM 104	80.7	04/10/2021	
21-03-03739-051	149.9-70	03/09/2021	RM 105	34.4	04/10/2021	
21-03-03739-052	149.9-71	03/09/2021	RM 105	39.4	04/10/2021	
21-03-03739-053	149.9-72	03/09/2021	RM 105	16.2	04/10/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03739

Project/Test Address: 2020L-149.9; Gaskill Prep; 910 Hyde Parke Blvd;
Niagara Falls, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03739-054	149.9-73	03/09/2021	RM 107	18.9	04/10/2021	
21-03-03739-055	149.9-74	03/09/2021	RM 107	20.3	04/11/2021	
21-03-03739-056	149.9-75	03/09/2021	RM 107	113	04/10/2021	
21-03-03739-057	149.9-76	03/09/2021	RM 106	2.22	04/10/2021	
21-03-03739-058	149.9-77	03/09/2021	GIRL'S LAV	6.96	04/10/2021	
21-03-03739-059	149.9-78	03/09/2021	GIRL'S LAV	3.59	04/10/2021	
21-03-03739-060	149.9-80	03/09/2021	GIRL'S LAV	2.26	04/10/2021	
21-03-03739-061	149.9-81	03/09/2021	GIRL'S LAV	1.62	04/10/2021	
21-03-03739-062	149.9-82	03/09/2021	GIRL'S LAV	1.88	04/10/2021	
21-03-03739-063	149.9-83	03/09/2021	GIRL'S LAV	1.97	04/10/2021	
21-03-03739-064	149.9-84	03/09/2021	GIRL'S LAV	2.22	04/10/2021	
21-03-03739-065	149.9-85	03/09/2021	GIRL'S LAV	3.17	04/10/2021	
21-03-03739-066	149.9-86	03/09/2021	GIRL'S LAV	2.65	04/10/2021	
21-03-03739-067	149.9-88	03/09/2021	RM 108	1.61	04/10/2021	
21-03-03739-068	149.9-89	03/09/2021	CLINIC	1.13	04/10/2021	
21-03-03739-069	149.9-90	03/09/2021	RM 112	<1.00	04/10/2021	
21-03-03739-070	149.9-92	03/09/2021	BOY'S LAV	3.05	04/10/2021	
21-03-03739-071	149.9-93	03/09/2021	BOY'S LAV	3.10	04/10/2021	
21-03-03739-072	149.9-94	03/09/2021	BOY'S LAV	2.40	04/10/2021	
21-03-03739-073	149.9-95	03/09/2021	BOY'S LAV	2.80	04/10/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03739

Project/Test Address: 2020L-149.9; Gaskill Prep; 910 Hyde Parke Blvd;
Niagara Falls, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03739-074	149.9-96	03/09/2021	BOY'S LAV	1.51	04/10/2021	
21-03-03739-075	149.9-97	03/09/2021	BOY'S LAV	1.34	04/10/2021	
21-03-03739-076	149.9-98	03/09/2021	BOY'S LAV	<1.00	04/10/2021	
21-03-03739-077	149.9-102	03/09/2021	RM 115	307	04/12/2021	
21-03-03739-078	149.9-103	03/09/2021	RM 116	<1.00	04/10/2021	

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Chain of Custody Document

Submitted to: (Lab Name) EHS

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

STOHL Job # 2020L-149.9Client: Niagara Falls CSD Contact: Earl SmealBuilding: Gaskill Prep Location: 910 Hyde Park Blvd. Niagara Falls, NY**LEAD**

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
149.9-1	rm 406	S	1:30
149.9-3	rm 400	S	1:31
149.9-5	Girl's Lav	S	1:32
149.9-6	Girl's Lav	S	1:33
149.9-7	Girl's Lav	S	1:34
149.9-8	Girl's Lav	S	1:35
149.9-9	Girl's Lav	S	1:36
149.9-14	Boy's Lav	S	1:37
149.9-15	Boy's Lav	S	1:38
149.9-16	Boy's Lav	S	1:39
149.9-17	Boy's Lav	S	1:40
149.9-18	Boy's Lav	S	1:41
149.9-21	rm 325	S	1:42
149.9-22	rm 323	S	1:43
149.9-23	rm 323	S	1:44
149.9-24	rm 323	S	1:45
149.9-25	rm 322	S	1:46
149.9-26	Cafeteria	Well Fill	1:47

21-03-03739



Due Date:
04/14/2021
(Wednesday)
AE

Notes:Please e-mail lab results to labs@stohlenv.com☒ If checked, also e-mail results to:Ehenderson@StohlEnv.com

Sampled By: Drew Theal Print Name Stohl Env: Drew Theal Date: 3/9/2021

Relinquished By: E. Henderson Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): K. Harris Date: 3/17/21 Time: 3:22 pm

Sample Login (Name / Lab): T. Lohman Date: 4/6/21 Time: 10g

Analysis (Name / Lab): Gary O'Neil Date: 4/12/21 Time: 4:57 pm

QA/QC Review (Name / Lab): Melanie Date: 4/14/21 Time: 3pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLNENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-149.9

Client: Niagara Falls CSD

Contact: Earl Smeal

Building: Gaskill Prep

Location: 910 Hyde Park Blvd. Niagara Falls, NY

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
149.9-27	Cafeteria	S	1:48
149.9-28	Cafeteria	Well Fill	1:49
149.9-29	Cafeteria	Well Fill	1:50
149.9-30	Kitchen	Sprayer	1:51
149.9-31	Kitchen	S	1:52
149.9-32	Kitchen	Soup Pot	1:53
149.9-33	Kitchen	S	1:54
149.9-34	Kitchen	S	1:55
149.9-35	Kitchen	S	1:56
149.9-36	Kitchen	S	1:57
149.9-37	Kitchen	S	1:58
149.9-39	Girl's Lav	S	1:59
149.9-40	Girl's Lav	S	2:00
* 149.9-41	Girl's Lav	S	2:01
149.9-43	Girl's Lav	S	2:02
149.9-44	Men's lav	S	2:03
149.9-46	rm 210B	S	2:04
149.9-47	Women's lav	S	2:05

↓
 CAP
 BROKEN
 BOTTLE FOUND EMPTY. (KTB 3/17/21)

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Drew Theal Print Name Stohl Env: Drew Theal Date: 3/9/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): K. Harris Date: 3.17.21 Time: 3:22 pm

Sample Login (Name / Lab): T. Bohannon Date: 4/6/21 Time: 10g

Analysis (Name / Lab): Gary Ode Date: 4/14/21 Time: 4:57 pm

QA/QC Review (Name / Lab): Muhler Date: 4/14/21 Time: 3 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

Submitted to: (Lab Name) EHS

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

STOHL Job # 2020L-149.9

Client: Niagara Falls CSD

Contact: Earl Smeal

Building: Gaskill Prep

Location: 910 Hyde Park Blvd. Niagara Falls, NY

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
149.9-48	Women's lav	S	2:06
149.9-50	Boy's Lav	S	2:07
149.9-51	Boy's Lav	S	2:08
149.9-52	Boy's Lav	S	2:09
149.9-53	Boy's Lav	S	2:10
149.9-54	Boy's Lav	S	2:11
149.9-57B	Girl's Gym	DFB	2:12
149.9-58B	Boy's Gym	DFB	2:13
149.9-61	Boy's Locker Room	S	2:14
149.9-62	Boy's Locker Room	S	2:15
149.9-65	Girl's Locker Room	S	2:16
149.9-66	Girl's Locker Room	S	2:17
149.9-67	rm 101	S	2:18
149.9-68	rm 103	S	2:19
149.9-69	rm 104	S	2:20
149.9-70	rm 105	S	2:21
149.9-71	rm 105	S	2:22
149.9-72	rm 105	S	2:23

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Drew Theal Print Name Stohl Env: Drew Theal Date: 3/9/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): RTHARRIS Date: 3-17-21 Time: 3:22 pm

Sample Login (Name / Lab): T. HARRIS Date: 4/6/21 Time: 10:00

Analysis (Name / Lab): Gary O'Neil Date: 4/14/21 Time: 4:57 pm

QA/QC Review (Name / Lab): M. HARRIS Date: 4/14/21 Time: 3 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-149.9

Client: Niagara Falls CSD Contact: Earl Smeal

Building: Gaskill Prep Location: 910 Hyde Park Blvd. Niagara Falls, NY

LEAD	Turnaround
Water by SM 19, 21 - 23 3113B (-04, -10) <u>X</u>	<u>20 Days</u>

Sample #	Location	Outlet Type	Time
149.9-73	rm 107	S	2:24
149.9-74	rm 107	S	2:25
149.9-75	rm 107	S	2:26
149.9-76	rm 106	S	2:27
149.9-77	Girl's Lav	S	2:28
149.9-78	Girl's Lav	S	2:29
149.9-80	Girl's Lav	S	2:30
149.9-81	Girl's Lav	S	2:31
149.9-82	Girl's Lav	S	2:32
149.9-83	Girl's Lav	S	2:33
149.9-84	Girl's Lav	S	2:34
149.9-85	Girl's Lav	S	2:35
149.9-86	Girl's Lav	S	2:36
149.9-88	rm 108	S	2:37
149.9-89	Clinic	S	2:38
149.9-90	rm 112	S	2:39
149.9-92	Boy's Lav	S	2:40
149.9-93	Boy's Lav	S	2:41

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Drew Theal Print Name Drew Theal Stohl Env: Drew Theal Date: 3/9/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS Date: 3-17-21 Time: 3:22 pm

Sample Login (Name / Lab): Tisham Date: 4/6/21 Time: 10

Analysis (Name / Lab): Yong Oee Date: 4/12/21 Time: 4:57 pm

QA/QC Review (Name / Lab): Melanie Date: 4/14/21 Time: 3 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

